

## LIST OF VARIOUS TYPE TEST REPORTS (NABL ACCREDITED LABS)

Sr. No.	Report / Certificate No.	Date	Specification				Insulation	Type	I.D. (mm)	Busbar Size / Brass Terminals	Drawing No.
			Ratio	VA	Class	STC					
1	PLV/10/SC/1491	01.01.10	3 x 50/5	5	0.5	5 KA	RESIN	WP	-	25 x 3	5197
2	PLV/10/SC/1492	01.01.10	3 x 100/5	5	0.5	5 KA	RESIN	WP	-	25 x 3	5198
3	LSCM/0214	25.05.10	100/5	5	0.5	3 KA	TAPE	RING	30	-	5189
4	LSCM/0361	28.07.10	100/5	5	0.5	5 KA	RESIN / PLASTIC	RING	20	-	5171
5	LSCM/0362	28.07.10	200/5	5	0.5	5 KA	RESIN / PLASTIC	RING	40	-	5090/A
6	LSCM/0853	19.08.10	50/5	1	0.5S	3 KA	RESIN	WP	-	12.5 x 3 / 2	5218/A
7	LSCM/0852	19.08.10	100/5	1	0.5S	5 KA	RESIN	RING	25	-	5215/A
8	LSCM/0850	19.08.10	200/5	1	0.5S	5 KA	RESIN	RING	30	-	5216/A
9	LSCM/0790	19.08.10	125/5	5	0.5	5 KA	RESIN	RING	26	-	5222
10	LSCM/1045	07.10.10	150/5	5	0.5	15 KA	RESIN	RING	30	-	5225
11	LSCM/1049	07.10.10	400/5	5	0.5	5 KA	RESIN	RING	55	-	5221
12	LSCM/1046	07.10.10	300/5	5	0.5	15 KA	RESIN	RING	40	-	5226
13	LSCM/1143	03.11.10	3 x 150/5	5	0.5	5 KA	RESIN	BP	-	25 x 5 / 1	5230
14	LSCM/1151	03.11.10	3 x 200/5	5	0.5	5 KA	RESIN	BP	-	25 x 5 / 1	5231
15	LSCM/1327	26.11.10	3 x 50/5	5	0.2S	7.5 KA	RESIN	WP	-	25 x 3 / 8	5234
16	LSCM/1328	26.11.10	3 x 100/5	5	0.2S	7.5 KA	RESIN	WP	-	25 x 5	5235
17	LSCM/1378	23.12.10	100/5	5	0.5S	5 KA	RESIN / PLASTIC	RING	20	-	5223
	HCCT/07/1293-1	09.01.11									
18	LSCM/1379	23.12.10	200/5	5	0.5S	5 KA	RESIN / PLASTIC	RING	40	-	5224
	HCCT/07/1293-2	09.01.11									
19	LSCM/1487	31.12.10	4 x 100/5	5	0.2S	5 KA	RESIN	WP	-	25 x 5	5244
STC on all 4 Phases / 11 Sec. Terminals											
20	LSCM/1563	20.01.11	4 x 50/5	5	0.2S	7.5 KA	RESIN	WP	-	25 x 3	5243
STC on all 4 Phases / 11 Sec. Terminals											
21	LSCM/1647	10.02.11	4 x 50/5	5	0.2S	7.5 KA	RESIN	WP	-	25 x 3	5248
STC on all 4 Phases / 12 Sec. Terminals											
22	LSCM/1648	10.02.11	4 x 100/5	5	0.2S	7.5 KA	RESIN	WP	-	25 x 3	5249
STC on all 4 Phases / 12 Sec. Terminals											
23	LSCM/1732	04.03.11	800/5	5	0.5	5 KA	RESIN	RING	80	-	5227
24	LSCM/1733	04.03.11	600/5	5	0.5	5 KA	RESIN	RING	55	-	5250
25	LSCM/607	20.07.11	50/5	5	0.5	3 KA	RESIN	WP	-	17 x 3	5259
26	LSCM/331	21.07.11	100/5	3.75	0.5	5 KA	FIBRE TAPE	RING	30	-	5260
27	LSCM/332	21.07.11	150/5	3.75	0.5	5 KA	FIBRE TAPE	RING	30	-	5261
28	LSCM/1040	10.10.11	200/5	5	0.5S	5 KA	RESIN	RING	30	-	5258
29	LSCM/1180	16.11.11	400/5	5	0.5	15 KA	RESIN	RING	55	-	5290
30	LSCM/1477	18.02.12	125/5	1	0.5	5 KA	RESIN	RING	30	-	5292/A
31	LSCM/0408	25.07.12	100/5	5	0.5	5 KA	CYCLO RESIN	RING	30	-	5316A
32	LSCM/456	25.07.12	200/5	5	0.5	5 KA	RESIN	BP	-	20 x 5	5317A
33	LSCM/0614	12.09.12	1500/5	5	0.5	5 KA	CYCLO RESIN	RING	75	-	5318A
34	LSCM/0571	12.09.12	300/5	5	0.5	5 KA	RESIN	RING	40	-	5180
35	LSCM/0570	12.09.12	200/5	5	0.5	5 KA	RESIN	RING	40	-	5183

## LIST OF VARIOUS TYPE TEST REPORTS (NABL ACCREDITED LABS)

Sr. No.	Report / Certificate No.	Date	Specification				Insulation	Type	I.D. (mm)	Busbar Size / Brass Terminals	Drawing No.
			Ratio	VA	Class	STC					
36	LSCM/0683	09.11.12	50/5	5	0.5	5 KA	RESIN	WP	-	17 x 3	5364
37	LSCM/684	09.11.12	100/5	5	0.5	5 KA	RESIN	RING	25	-	5179
38	LSCM/1215	28.02.13	100/5	5	0.5S	5 KA	RESIN	WP	-	17 x 3	5323
39	LSCM/1217	05.03.13	50/5	5	0.5S	5 KA	RESIN	WP	-	17 x 3	5324
40	LSCM/0062	15.05.13	800/5	5	0.5S	5 KA	CYCLO RESIN	RING	60	-	5318
41	LSCM/0060	15.05.13	400/5	5	0.5S	5 KA	CYCLO RESIN	RING	45	-	5318D
42	LSCM/0061	15.05.13	200/5	5	0.5S	5 KA	CYCLO RESIN	RING	45	-	5318E
43	LSCM/1506	15.05.13	100/5	5	0.5	15 KA	RESIN	RING	25	-	5376
44	LSCM/1507	15.05.13	200/5	5	0.5	15 KA	RESIN	RING	40	-	5381
45	RP-1314-8545	04.09.13	200/5	5	0.5	5 KA	RESIN	RING	30	-	5251
46	RP-13-14-11690	10.10.13	125/5	1	0.5S	5 KA	RESIN	RING	25	-	5353
47	YMPL/243890/56465	18.01.14	200/5	5	0.5S	5 KA	RESIN	RING	40	-	5224
48	YMPL/243893/56466	18.01.14	100/5	5	0.5S	5 KA	RESIN	RING	20	-	5223
49	YMPL/253601/57193	06.02.14	50/5	5	0.5	3 KA	RESIN	WP	-	12 x 3	5452
50	YMPL/253607/57194	06.02.14	100/5	5	0.5	5 KA	RESIN	WP	-	12 x 3	5453
51	RP-13-14-022849	15.02.14	600/5	5	0.5S	5 KA	CYCLO RESIN	RING	60	-	5318F
52	RP-13-14-023850	25.02.14	200/5	5	0.5	5 KA	RESIN	RING	40	-	5450
53	RP-13-14-023849	26.02.14	4 x 150/5	2.5	0.5	10 KA	RESIN		-	20 x 5	5342A
54	RP-1314-023851	04.03.14	300/5	5	0.5	5 KA	RESIN	RING	45	-	5451
55	RP-1415-001213	21.04.14	200/5	5	0.5S	5 KA	RESIN	RING	30	-	5419
56	RP-1415-001225	21.04.14	200/5	5	0.5S	5 KA	RESIN	RING	30	-	5419
57	RP-1415-001207	21.04.14	100/5	5	0.5S	5 KA	RESIN	RING	20	-	5420
58	RP-1415-001204	21.04.14	100/5	5	0.5S	5 KA	RESIN	RING	20	-	5420
59	RP-1415-002113	28.04.14	600/5	5	0.5	5 KA	RESIN	RING	55	-	5456
60	RP-1415-002216	29.04.14	500/5	5	0.5	5 KA	RESIN	RING	55	-	5456A
61	RP-1415-002215	01.05.14	400/5	5	0.5	5 KA	RESIN	RING	45	-	5457
62	RP-1415-004408	20.05.14	1400/5	2.5	0.5	25 KA	RESIN	RING	90	-	5337
63	YMPL/254930/60228	26.06.14	50/5	3.75	1.0	5 KA	FIBRE TAPE	RING	35	-	5329
64	RP-1415-023151	12.11.14	400/5	5	0.5S	5 KA	RESIN	RING	55	-	5485
65	RP-1415-025267	01.12.14	1600/5	5	0.5	5 KA	RESIN	RECT.	-	-	5473
66	RP-1415-025783	04.12.14	600/5	5	0.5	25 KA	CYCLO RESIN	RING	70	-	5472
67	RP-1415-026360	09.12.14	100/5	5	0.5	5 KA	RESIN	WP	-	17 x 3 x 33.5	5323
68	RP-1415-030314A	17.01.15	300/5	5	0.5S	5 KA	CYCLO RESIN	RING	45	-	5318G
69	RP-1415-030315A	17.01.15	500/5A	5	0.5S	5 KA	CYCLO RESIN	RING	45	-	5318H
70	RP-1415-040814	31.03.15	100/5A	5	0.5	15 KA	RESIN	RING	25	-	5376
71	RP-1516-003695	02.05.15	200/5A	5	0.5S	5 KA	RESIN	RING	30	-	5419
72	RP-1516-003694	02.05.15	200/5A	5	0.5S	5 KA	RESIN	RING	30	-	5419
73	RP-1516-008236	30.05.15	100/5A	2.5	0.5S	5 KA	CYCLO RESIN	RING		-	5506
74	RP-1516-017506	07.08.15	200/5A	1	0.5S	5 KA	RESIN	RING	30	-	5216A
75	RP-1516-028559	30.10.15	75/5A	1	0.5S	5 KA	RESIN	RING	20	-	5508
76	RP-1516-032286	30.10.15	200/5A	1	0.5S	5 KA	RESIN	RING	30	-	5540

## LIST OF VARIOUS TYPE TEST REPORTS (NABL ACCREDITED LABS)

Sr. No.	Report / Certificate No.	Date	Specification				Insulation	Type	I.D. (mm)	Busbar Size / Brass Terminals	Drawing No.
			Ratio	VA	Class	STC					
77	RP-1516-028829	31.10.15	100/5A	1	0.5S	5 KA	RESIN	RING	25	-	5215B
78	RP-1516-045410	27.02.16	200/5A	5	0.5	5 KA	TAPE	RING	30	-	5555
79	RP-1617-007702	19.05.16	50/5A	5	0.5	5 KA	RESIN	WP	NA	17 x 3	5389
80	RP-1617-007703	19.05.16	100/5A	5	0.5	5 KA	RESIN	WP	NA	17 x 3	5560
81	RP-1617-007705	19.05.16	125/5A	5	0.5S	5 KA	RESIN	RING	25	-	5179
82	RP-1617-025263	29.08.16	100/5A	5	0.5	5 KA	RESIN	RING	30	-	5105
83	RP-1617-029124	22.09.16	630/5A	10	0.2S	5 KA	RESIN	RING	55	-	5390
84	RP-1617-034294	24.10.16	100/5A	5	0.5S	5 KA	RESIN	WP	-	-	5389
85	RP-1617-038269	24.11.16	200/5A	5	0.5S	5 KA	RESIN	RING	40	-	5593
86	RP-1617-050214	30.01.17	200/5A	5	0.5	5 KA	TAPE	RING	SAMPLE TESTED		
87	RP-1617-050215	30.01.17	200/5A	5	0.5	5 KA	TAPE	RING			
88	RP-1617-050216	30.01.17	200/5A	5	0.5	5 KA	TAPE	RING			
89	RP-1617-055666	23.02.17	100/5A	5	0.5	5 KA	TAPE	RING	30	-	5683

## LIST OF VARIOUS TYPE TEST REPORTS - 11 KV C.T. (NABL ACCREDITED LABS)

SR. NO.	Report No.	Date	Specification				Insulation	Type	I.D. (mm)	Busbar Size / Brass Terminals	Drawing No.
			Ratio	VA	Class	STC					
1	LSCM/0620	05.09.12	60-35/5	15	5P10	13.1 KA for 1 Sec	RESIN	WP	-	40 x 6	5340
2	RP-1314-014990	23.11.13	100/5A	10	0.5	13.1 KA for 1 Sec	RESIN	WP	-	25 x 25 / M10	5429
3	RP-1415-003690	12.05.14	5/5A	10	0.5	3 KA for 1 Sec	RESIN	WP	-	25 x 25 / M10	5427
4	RP-1415-003691	12.05.14	25/5A	10	0.5	6.7 KA for 1 Sec	RESIN	WP	-	25 x 25 / M10	5428
5	RP-1415-015368	12.05.14	100/5A	10	0.2S	13.1 KA for 1 Sec	RESIN	WP	-	25 x 25 / M10	5466
6	RP-1415-017581	11.09.14	50/5A	15	0.5S	13.1 KA for 1 Sec	RESIN	WP	-	-	5430B
7	RP-1415-033568	11.02.15	600-300/5-5A	5\15	0.5/5P10	18.4 KA for 3 Sec	RESIN	BP	-	M10	5305A
8	RP-1516-000188	02.04.15	200-100/5-5A	5\15	0.5/5P10	18.4 KA for 3 Sec	RESIN	WP	-	M12	5474
9	RP-1516-028943	31.10.15	11000/V3/110/V 3 V	50	0.5	N.A.	RESIN	WP	-	M5	5533
10	RP-1617-044410	28.12.16	200-100/5-5A	2.5\15 VA	0.5/5P10	25 kA for 3 Sec	RESIN	WP	-	M10	5675